



Retail
Hospitality
Healthcare
Architectural Lighting
Signage
Casino Design
Residential

eoslight.com



LUMINAIRE PHOTOMETRIC TEST REPORT

EOS-HP-CRYSTAL FRAME-2700k-24 x 24-HP-4SL_IESNA95

NAME: EOS-HP-Crystal Frame- CF-24V-24x24-2700-ASL-HP	TYPE: EOS HP-Crystal Frame	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: EOS	SUR.:	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA				Eff: 38.95 lm/W
MODEL		Imax(cd)	330.9	S/MH(C0/180)	1.74	
NOMINAL POWER(W)	35.1	LOR(%)	89.4	S/MH(C90/270)	1.79	
RATED VOLTAGE(V)	24	TOTAL FLUX(lm)	1381.1	η UP,DN(C0-180)	0.0,43.0	
NOMINAL FLUX(lm)	1545.08	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.0,46.4	
LAMPS INSIDE	1	η up(%)	0.0	CIBSE SHR NOM	1.75	
TEST VOLTAGE(V)	24.25	η down(%)	89.4	CIBSE SHR MAX	1.75	

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C Range: 0 - 360DEG
C Interval: 5.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: DAMIN
Test Date: 2019-06-21

γ Range: 0 - 90DEG
 γ Interval: 0.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.293
Humidity: 65.0%
Test Distance: 9.180m [K=1.0000]
Remarks: DWY




Retail
Hospitality
Healthcare
Architectural Lighting
Signage
Casino Design
Residential

eoslight.com

AAI Figure

NAME: EOS-HP-Crystal Frame- CF-24V-24x24-2700-ASL-HP	TYPE: EOS HP-Crystal Frame	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.: EOS	SUR.:	Shielding Angle:



Note: The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 5.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: DAMIN
Test Date: 2019-06-21

γ Range: 0 - 90DEG
γ Interval: 0.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.293
Humidity: 65.0%
Test Distance: 9.180m [K=1.0000]
Remarks: DWY







γ Range: 0 - 90DEG
γ Interval: 0.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.293
Humidity: 65.0%
Test Distance: 9.180m [K=1.0000]
Remarks: DWY

